SAMPLE NAME	LOCATION (MACDONALD)	SAMPLE DATE	SAMPLE TIME	ANALYSIS DATE	RESULTS (PPB)
MacD 22-3	Unisex bathroom sink - room 176a	5/7/2016	12:23:00	5/16/2016	58.0
MacD 22-4	Unisex bathroom sink - room 176a	5/7/2016	12:26:00	5/16/2016	7.2
MacD 92-3	Sink room 110	5/7/2016	12:59:00	5/16/2016	Below Detection Limits
MacD 92-4	Sink room 111	5/7/2016	13:02:00	5/16/2016	Below Detection Limits
MacD 99-3	Sink in kitchen area	5/7/2016	14:50:00	5/16/2016	12.0
MacD 99-4	Sink in kitchen area	5/7/2016	14:53:00	5/16/2016	3.7
MacD 103-3	Sink in kitchen area	5/7/2016	14:39:00	5/16/2016	1.1
MacD 103-4	Sink in kitchen area	5/7/2016	14:42:00	5/16/2016	1.1
MacD 106-3	Sink in kitchen area	5/7/2016	14:45:00	5/16/2016	Below Detection Limits
MacD 106-4	Sink in kitchen area	5/7/2016	14:47:00	5/16/2016	Below Detection Limits
MacD 107-3	Sink in kitchen area	5/7/2016	14:33:00	5/16/2016	Below Detection Limits
MacD 107-4	Sink in kitchen area	5/7/2016	14:34:00	5/16/2016	Below Detection Limits
MacD 118-3	Sink room 260 (not used)	5/7/2016	13:27:00	5/16/2016	1.4
MacD 118-4	Sink room 260 (not used)	5/7/2016	13:29:00	5/16/2016	Below Detection Limits
MacD 119-3	Sink room 260 (not used)	5/7/2016	13:16:00	5/16/2016	4.6
MacD 119-4	Sink room 260 (not used)	5/7/2016	13:18:00	5/16/2016	Below Detection Limits
MacD 120-3	Sink room 260 (not used)	5/7/2016	13:21:00	5/16/2016	1.1
MacD 120-4	Sink room 260 (not used)	5/7/2016	13:23:00	5/16/2016	1.3
MacD 121-3	Sink room 260 (not used)	5/7/2016	13:37:00	5/16/2016	1.8
MacD 121-4	Sink room 260 (not used)	5/7/2016	13:39:00	5/16/2016	2.0
MacD 122-3	Sink room 260 (not used)	5/7/2016	13:43:00	5/16/2016	1.3
MacD 122-4	Sink room 260 (not used)	5/7/2016	13:44:00	5/16/2016	1.5
MacD 157-3	Sink in room 260	5/7/2016	13:47:00	5/16/2016	Below Detection Limits
MacD 157-4	Sink in room 260	5/7/2016	13:50:00	5/16/2016	5.0
MacD 201-3	Sink in room 150 - instructor station	5/7/2016	14:10:00	5/16/2016	Below Detection Limits
MacD 201-4	Sink in room 150 - instructor station	5/7/2016	14:12:00	5/16/2016	Below Detection Limits
MacD 203-3	Sink in room 122 - instructor station	5/7/2016	14:02:00	5/16/2016	Below Detection Limits
MacD 203-4	Sink in room 122 - instructor station	5/7/2016	14:04:00	5/16/2016	Below Detection Limits
MacD 35-1	Drinking fountain - outside auditorium	5/7/2016	12:45:00	5/16/2016	Below Detection Limits
MacD 35-2	Drinking fountain - outside auditorium	5/7/2016	12:46:00	5/16/2016	Below Detection Limits
MacD 64-1	Drinking fountain - outside room 135	5/7/2016	12:47:00	5/16/2016	2.3
MacD 64-2	Drinking fountain - outside room 135	5/7/2016	12:48:00	5/16/2016	1.4
MacD 129-1	Sink room 233	5/7/2016	13:54:00	5/16/2016	2.8
MacD 129-2	Sink room 233	5/7/2016	13:55:00	5/16/2016	1.3
MacD 250-1	Sink room 101a - near main office	5/7/2016	12:31:00	5/16/2016	1.3
MacD 250-2	Sink room 101a - near main office	5/7/2016	12:33:00	5/16/2016	1.5
MacD 251-1	Sink room 109	5/7/2016	12:38:00	5/16/2016	1.5
MacD 251-2	Sink room 109	5/7/2016	12:39:00	5/16/2016	Below Detection Limits
MacD 258-1	Sink room 260 (not used)	5/7/2016	13:34:00	5/16/2016	92.0
MacD 258-2	Sink room 260 (not used)	5/7/2016	13:34:00	5/16/2016	22.0
MacD 259-1	Sink in room 182	5/7/2016	14:27:00	5/16/2016	15.0
MacD 259-2	Sink in room 182	5/7/2016	14:27:00	5/16/2016	8.0
MacD 260-1	Sink in room 182	5/7/2016	14:28:00	5/16/2016	Below Detection Limits
MacD 260-2	Sink in room 182	5/7/2016	14:29:00	5/16/2016	Below Detection Limits
MacD 261-1	Sink in room 182	5/7/2016	14:25:00	5/16/2016	19.0
MacD 261-2	Sink in room 182	5/7/2016	14:26:00	5/16/2016	44.0